GUIDELINES FOR DRINKING-WATER QUALITY: FOURTH EDITION INCORPORATING THE FIRST AND SECOND ADDENDA

Guideline value derivation	
 allocation to water 	10% of upper limit of ADI
weight	60 kg adult
consumption	2 litres/day
Additional comments	The guideline value derived from the 1992 assessment of the Joint FAO/WHO Meeting on Pesticide Residues (JMPR) was very similar to the guideline value derived in the second edition, which was therefore retained.
Assessment date	2003
Principal references	FAO/WHO (1993) Pesticide residues in food—1992 evaluations WHO (2003) Aldicarb in drinking-water

Aldicarb is one of the most acutely toxic pesticides in use, although the only consistently observed toxic effect with both long-term and single-dose administration is acetylcholinesterase inhibition. It is converted to the sulfoxide and sulfone. Aldicarb sulfoxide is a more potent inhibitor of acetylcholinesterase than aldicarb itself, whereas aldicarb sulfone is considerably less toxic than either aldicarb or the sulfoxide. The weight of evidence indicates that aldicarb, aldicarb sulfoxide and aldicarb sulfone are not genotoxic or carcinogenic. IARC has concluded that aldicarb is not classifiable as to its carcinogenicity (Group 3).

Aldrin and dieldrin

Aldrin (CAS No. 309-00-2) and dieldrin (CAS No. 60-57-1) are chlorinated pesticides that are used against soil-dwelling pests, for wood protection and, in the case of dieldrin, against insects of public health importance. Since the early 1970s, many countries have either severely restricted or banned the use of both compounds, particularly in agriculture. The two compounds are closely related with respect to their toxicology and mode of action. Aldrin is rapidly converted to dieldrin under most environmental conditions and in the body. Dieldrin is a highly persistent organochlorine compound that has low mobility in soil, can be lost to the atmosphere and bioaccumulates. Dietary exposure to aldrin/dieldrin is very low and decreasing.

Guideline value	Aldrin and dieldrin (combined): 0.000 03 mg/l (0.03 μg/l)
Occurrence	Seldom detected in drinking water; concentrations of aldrin and dieldrin in drinking-water normally less than 0.01 μ g/l; rarely present in groundwater
Provisional tolerable daily intake (PTDI)	0.1 µg/kg body weight (combined total for aldrin and dieldrin), based on no-observed-adverse-effect levels (NOAELs) of 1 mg/kg diet in the dog and 0.5 mg/kg diet in the rat, which are equivalent to 0.025 mg/kg body weight per day in both species, and applying an uncertainty factor of 250 based on concern about carcinogenicity observed in mice
Limit of detection	0.003 μg/l for aldrin and 0.002 μg/l for dieldrin by GC with electron capture detector (ECD)
Treatment performance	0.02 μg/l should be achievable using coagulation, GAC or ozonation

12. CHEMICAL FACT SHEETS

Guideline value derivation	
allocation to water	1% of PTDI (In view of the reduction in exposure from food this value is probably very conservative.)
weight	60 kg adult
consumption	2 litres/day
Additional comments	Aldrin and dieldrin are listed under the Stockholm Convention on Persistent Organic Pollutants. Hence, monitoring may occur in addition to that required by drinking-water guidelines.
Assessment date	2003
Principal references	FAO/WHO (1995) Pesticide residues in food—1994 evaluations WHO (2003) Aldrin and dieldrin in drinking-water

Both compounds are highly toxic in experimental animals, and cases of poisoning in humans have occurred. Aldrin and dieldrin have more than one mechanism of toxicity. The target organs are the central nervous system and the liver. In long-term studies, dieldrin was shown to produce liver tumours in both sexes of two strains of mice. It did not produce an increase in tumours in rats and does not appear to be genotoxic. IARC has classified aldrin and dieldrin in Group 3 (not classifiable as to its carcinogenicity to humans). Exposure through food has decreased significantly with the dramatic reduction in use.

Aluminium

Aluminium is the most abundant metallic element and constitutes about 8% of Earth's crust. Aluminium salts are widely used in water treatment as coagulants to reduce organic matter, colour, turbidity and microorganism levels. Such use may lead to increased concentrations of aluminium in finished water. Where residual concentrations are high, undesirable colour and turbidity may ensue. Concentrations of aluminium at which such problems may occur are highly dependent on a number of water quality parameters and operational factors at the water treatment plant. Aluminium intake from foods, particularly those containing aluminium compounds used as food additives, represents the major route of aluminium exposure for the general public. The contribution of drinking-water to the total oral exposure to aluminium is usually less than 5% of the total intake.

Reason for not establishing a guideline value	A health-based value of 0.9 mg/l could be derived from the JECFA provisional tolerable weekly intake (PTWI), but this value exceeds practicable levels based on optimization of the coagulation process in drinking-water plants using aluminium-based coagulants: 0.1 mg/l or less in large water treatment facilities and 0.2 mg/l or less in small facilities
Assessment date	2009
Principal references	FAO/WHO (2007) Aluminium (from all sources, including food additives) IPCS (1997) <i>Aluminium</i> WHO (2010) <i>Aluminium in drinking-water</i>